



WATER TIGHT LID, FRP WITH PADLOCK (STANDARD)

STRAIN RELIEF CORD CONNECTOR

PROTECTIVE CABLE SHROUD (FRP)

POWER/ALARM CABLE 12-6 W/GND.

ELECTRICAL QUICK DISCONNECT (EQD)

CORE CONTROL COMPARTMENT BREATHER

INTERNAL WELL VENT 2.0" DIA.

QUICK DISCONNECT ASSY. (304 S.S.)

INLET, GROMMET TO ACCEPT 4.50" O.D. PVC PIPE (STANDARD). DUST COVER SUPPLIED FOR SHIPMENT (NOT SUITABLE FOR BURIAL)

SS CAST BALL VALVE

DISCHARGE 1 1/4" FNPT

1-1/4" DISCHARGE LINE (304 S.S.)

CHECK VALVE (PVC)

41" TO DISCHARGE

ALARM

ON

OFF

35" TO INLET

ANTI-SIPHON VALVE (PVC)

14" 24 gal.

18" 32 gal.

26" 47 gal

30" DIA.

NOTE: A CONCRETE ANCHOR IS REQUIRED TO PREVENT TANK FROM FLOATING.

SEMI-POSITIVE DISPLACEMENT TYPE PUMP DIRECTLY DRIVEN BY A 1 HP MOTOR CAPABLE OF DELIVERING 9 gpm AT 138' T.D.H.

MODEL 2010 AS MANUFACTURED BY ENVIRONMENT/ONE CORPORATION OR EQUAL.

(PS-2) CITY OF SACO GRINDER PUMP STATION

N.T.S.